



PHIFER
INCORPORATED

3 July 2013

MIRAGE SCREEN SYSTEMS INC.

Re: Flame Resistance of Woven Fabrics

Fabrics covered under this document are as follows:

1. 18x14 Mesh Fiberglass Insect Screen Type II, Class 2 Vinyl Coated
 - A. All Colors
 - B. Fill Yarn 0.013 Diameter Vinyl Coated Fiberglass
 - C. Warp Yarn 0.013 Diameter Vinyl Coated Fiberglass

PHIFER INCORPORATED certifies that the materials listed above manufactured in Tuscaloosa, Alabama, U.S.A., are in compliance* with following standard(s):

1. Federal Specification L-S-125B Insect Screening, Non-Metallic
Material has been tested and complies with section 4.4.15 Flame Resistance which states after the 2x10" sample has been in contact with the flame source for a period of 12 seconds, the sample must self-extinguish within 10 seconds.
2. Federal Motor Vehicle Safety Standard No. 302: Flammability of Interior Materials for Passenger Cars, Multipurpose Passenger Vehicles, Trucks and Buses.



PHIFER
INCORPORATED

3 July 2013

MIRAGE SCREEN SYSTEMS INC.

Re: Flame Retardance Certificate

PHIFER INCORPORATED certifies that the material described below manufactured in Tuscaloosa, Alabama, U.S.A., and furnished by our firm:

Vinyl Coated Fiberglass Insect Screening Type II, Class 1, 18x16 Mesh,
All Colors

is in compliance with the following standard(s):

1. Federal Specification L-S-125B Insect Screening, Non-Metallic.
2. Federal Motor Vehicle Safety Standard No. 302: Flammability of Interior Materials for Passenger Cars, Multipurpose Passenger Vehicles, Trucks and Buses.
3. National Fire Protection Association, NFPA No. 101, "Life Safety Code", Class "A" Rating. (Tested in accordance to ASTM E84.)
FLAME SPREAD INDEX = 5 SMOKE DEVELOPED VALUE = 155
4. International Building Code (IBC) Section 903.1, Class I. (Tested in accordance to ASTM E84.)
5. CPAI-84: A Specification for Flame Resistance Material used in Camping Tentage.